

Environmental Health Services Division

401 Fifth Avenue, Suite 1100
Seattle, WA 98104-1818

206-205-4394 Fax 206-296-0189
TTY Relay: 711

www.kingcounty.gov/health



**COMMUNITY ENVIRONMENTAL HEALTH
PLUMBING & GAS PIPING SECTION**

PRODUCT / METHOD RESEARCH REPORT

DATE: July 23, 2010

FILE NO: 10-002

PRODUCT / METHOD: Thermafit Hinge Type Plastic No-Hub Couplings

Public Health – Seattle & King County does hereby approve for use within its jurisdiction the following product/method: Thermafit Hinge Type Plastic No-Hub Couplings.

Description: Coupling for connection of cast iron DWV pipe and fitting systems that utilizes a plastic hinged sleeve.

Comments: The product has received an IAPMO listing and conforms to IAPMO IGC 257-2009a. The rubber-type gasket conforms to applicable standards for no-hub couplings and the hinged shield meets the strength and torque requirements for no-hub couplings.


Approval is subject to the following conditions:

- Shall be installed per the manufacturer's installation instructions and the Uniform Plumbing Code.

Approval is hereby granted under the provisions of section(s):

2009 Uniform Plumbing Code, Section 301.2 – Alternate Materials and Methods Equivalency.

Approved by:



Dave Cantrell
Chief Plumbing Inspector