

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHAL BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES

CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

RAYMOND S. CHAN, C.E., S.E.
INTERIM GENERAL MANAGER

Armond Sarkisian
Thermafit Industries, Inc.
15030 Keswick St.
Van Nuys, CA 91405

Telephone: 877-827-2782

Models:

EZC-112 (1-1/2"), EZC-200 (2"), EZC-300 (3"), EZC-400(4")

File Number: M-090175

Effective Date: 12/01/2009

Expiration Date: 12/01/2010

Manufacturer: THERMAFIT INDUSTRIES, INC.

Item: NO HUB COUPLING

PLEASE REFER TO THE APPLICATION NUMBER ON ALL CORRESPONDENCE, PHONE CALLS & SAMPLES

The item processed under the above file number has been tested, examined and found to comply with applicable Los Angeles Plumbing Code (LAPC) and/or Los Angeles Mechanical Code (LAMC) and is hereby approved unless revoked for cause.

This letter or the letterhead copy may not be reproduced for use in labeling or advertising, but copies of this letter may be used within your organization and shown as evidence of approval.

CONDITIONS OF APPROVAL:

- 1. These couplings are approved for joining hubless cast iron sewer, waste pipes above and below ground, inside and outside buildings in all occupancies.**
- 2. Installation shall be performed in a manner conforming to the code, applicable standards, the manufacture's printed instructions as required by section 94.310.4 of the Los Angeles Plumbing Code, 2008 Edition.**
- 3. The no hub coupling shall be identified with the manufacturer's name, part number and appropriate size.**

Each item shall have the name or trademark of manufacturer and model number where it will be visible for inspection.

In order to renew this approval, an application and reexamination fee must be submitted on or before the expiration date shown above. Arrangement shall be made to remove any test samples remaining in the Laboratory. Samples remaining after 21 days from the date of this notice will be shipped collect by the most convenient carrier or disposed of in accordance with applicable regulation.

Mark K Wang
Mechanical Testing Laboratory, Test Engineer

Michael Tharpe, Chief
Plumbing / Mechanical Inspection
Inspection Bureau